|   |   |                |                       | FILE: 62259                     |
|---|---|----------------|-----------------------|---------------------------------|
| 30  |   |                |                       | CLAMP TOP LINE POST             |
| 50  |   |                |                       | HORIZONTAL MOUNTING             |
|   |   |                |                       | 88 Kv CAT. NO. 62259            |
| I ENG. MGR.   | DIMENSIONS  |                |                       | ANSI CLASS 57-26                |
| 2 ENG.  | LEAKAGE DISTANCE  | IN             | 53.                   |                                 |
| PURCH.  | DRY ARCING DISTANCE   | IN             | 53<br>19 <del>1</del> |                                 |
| I MICTO.  | MECHANICAL VALUES   |                |                       |                                 |
| COST  | CANTILEVER STRENGTH   | LB             | 2,800                 |                                 |
| PROD.   | ELECTRICAL VALUES   |                |                       |                                 |
| INSP.<br>GLAZE  | 60 HERTZ FLASHOVER-DRY<br>60 HERTZ FLASHOVER-WET<br>IMPULSE FLASHOVER-POS.  | kV<br>kV<br>kV | 180<br>150<br>300     |                                 |
| BUSHING<br>MAKING   | RADIO INFLUENCE VOLTAGE DATA  |                |                       | MALL. IRON                      |
| SHIP.   | 60 HERTZ_TEST_VOLTAGE   |                |                       |                                 |
| ASSEM.  | RMS TO GROUND<br>MAXIMUM RIV @ 1000 kHz   | kV<br>uV       | 44<br>200             |                                 |
| MODEL<br>MACH.  | PACKING INFORMATION   |                |                       |                                 |
| 45  | NET WEIGHT PER 100<br>PACKED WEIGHT PER 100   | LB<br>LB       | 6850<br>7250          |                                 |
| TOOLING   | NO. IN STANDARD PACKAGE   | LD             | 1250                  |                                 |
| CER. LAB.   |   |                |                       |                                 |
| I E. MEDIA  |   |                |                       |                                 |
| THIS DRAWING IS THE PROPERTY OF<br>VICTOR INSULATORS, INC. AND CONTAINS<br>PROPRIETARY AND CONFIDENTIAL INFORMATION<br>MHICH MIST NOT BE DUPLICATED, USED,<br>OR DISCLOSED OTHER THAN AS EXPRESSLY<br>AUTHORIZED BY VICTOR INSULATORS, INC. |   |                |                       |                                 |
|   | APPROVED  |                | MALL<br>IRON          | BASE ØZ-9 +.015"<br>TAPPED HOLE |
|   | <u>E Schwalm at 6:59 am, May 17, 2008</u><br>i-16-08 REV'D TM Victor Insulators, Inc.<br>280 MAPLE AVENUE<br>VICTOR, NEW YORK 14564 62259 |                |                       |                                 |
|   | 5-22-98         TM         V         Z80 Min/Le AVENUE         VICTOR, NEW YORK 14564         O/2/2/9                                     |                |                       |                                 |
|   |   | 14-93          |                       | I                               |