

S

STATION POST	
CAT. NO. 1620 S	
500 kV	1,550 kV BIL
TR 379	

DIMENSIONS:

LEAKAGE DISTANCE IN 280

MECHANICAL VALUES:

CANTILEVER STRENGTH LB 1,700
 TENSION STRENGTH LB 20,000
 TORSION STRENGTH IN-LB 40,000
 COMPRESSION STRENGTH LB 60,000

ELECTRICAL VALUES:

IMPULSE FLASHOVER-POSITIVE kV 1,710
 60 HERTZ WITHSTAND-WET kV 620
 IMPULSE WITHSTAND kV 1,550

RADIO INFLUENCE VOLTAGE DATA:


60 HERTZ TEST VOLTAGE TO GROUND kV 318
 MAXIMUM R.I.V. @ 1000 kHz μ V 2,000

PACKAGING INFORMATION:



NET WEIGHT, LB 536
 PACKED WEIGHT LB 550
 NO. IN STANDARD PACKAGE 1/2

4 HOLES 5/8"-11 +.015 ON 5" B.C.


$\phi 6 \frac{1}{4}$ "




$\phi 9 \frac{1}{16}$ "



$\phi 9 \frac{3}{4}$ "



$\phi 8 \frac{1}{2}$ "



4 HOLES 3/4"-10 +.015 ON 7" B.C.

128" FILE: 1620 S

- 1 ENG. MGR
- 2 ENG
- PURCH.
- 1 MKTG.
- PLT.MGR.
- COST
- PRD.
- INSP
- GLAZE
- BUSHING
- MAKING
- SHIP
- ASSEM
- MODEL
- MACH.
- 45
- TOOLING
- CER LAB
- 1 EL LAB
- 1 E.MEDIA

THIS DRAWING IS THE PROPERTY OF VICTOR INSULATORS, INC. AND CONTAINS PROPRIETARY AND CONFIDENTIAL INFORMATION WHICH MUST NOT BE DUPLICATED, USED, OR DISCLOSED OTHER THAN AS EXPRESSLY AUTHORIZED BY VICTOR INSULATORS, INC.

APPROVED
By A. E. Schwalm at 3:07 pm, Feb 21, 2019



Victor Insulators, Inc.
 280 Maple Avenue
 Victor, New York 14564
 Telephone: (585)924-2127
 www.victorinsulators.com

1620 S