



**DIMENSIONS**

LEAKAGE DISTANCE	mm	2,629
DRY ARCING DISTANCE	mm	1,000
ANSI BALL SIZE		

**MECHANICAL VALUES**

SPECIFIED MECHANICAL LOD(SML)	kN	112
ROUTINE TEST LOAD(RTL)	kN	56

**ELECTRICAL VALUES**

RATED VOLTAGE	kV	115
LOW FREQUENCY FLASHOVER, DRY	kV	382
LOW FREQUENCY FLASHOVER, WET	kV	346
IMPULSE FLASHOVER, POSITIVE	kV	662
IMPULSE FLASHOVER, NEGATIVE	kV	705

**PACKING INFORMATION**

NET WEIGHT	kg	2.5
------------	----	-----

**APPROVED**  
By A. E. Schwalm at 8:15 am, Aug 24, 2023

DATE	08-23-23	TM
------	----------	----

SYSTEM VOLTAGE: 115 kV
SUSPENSION INSULATOR
T112-YB-1224-2629-AA



**Victor Insulators, Inc.**  
280 Maple Avenue  
Victor, New York, 14564  
Telephone: (585)924-2127  
www.victorinsulators.com

THIS DRAWING IS THE PROPERTY OF VICTOR INSULATORS, INC. AND CONTAINS PROPRIETARY AND CONFIDENTIAL INFORMATION WHICH MUST NOT BE DUPLICATED, USED, OR DISCLOSED OTHER THAN AS EXPRESSLY AUTHORIZED BY VICTOR INSULATORS, INC.

FILE: T112-YB-1224-2629-AA